



OFFICE OF THE DY. FIRE OFFICER,
KORAPUT CIRCLE, KORAPUT

No. 220/KPT CrI.

Dtd 12.01.2021

To

The Principal,
Sinai Public School, Laxmipur,
Dist- Koraput.

Ref: - Your application in Form-III requesting for Fire Safety Certificate.

Sub: - Regarding issuance of Fire Safety certificate in respect of Sinai Public School, Laxmipur, Dist- Koraput.

Sir,

With reference to the subject cited above this is to intimate that, as per Rule 3(j) of Odisha Fire Prevention and Fire safety (Amendment) Rules-2019, the following Educational Buildings are only required to obtain Fire safety certificate.

1. Having height of 12 mtr and above or,
2. Having a built up area of 1000 square meters or above, or
3. Having 03 storied buildings.

However, as shown in furnished plan, and undertaken verification by a team of Fire Service Officers on 07.01.2021, your educational institution contains total 02 Blocks having G+1 Floors only. Height of the Block is 07 mtr approximately & total built up area is 957 square meters approximately.

Hence, as per provisions of Rule 3(j) of Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019, Fire Safety Certificate (F.S.C) is not required to the afore-said educational buildings as on date of verification i.e 07.01.2021.

However you are requested to take sufficient First Aid Fire Fighting gadgets inside the building

Here with your application is disposed of accordingly.

Yours faithfully

Deputy Fire Officer
Koraput Circle
Koraput

SINAI PUBLIC SCHOOL
LAXMIPUR, KORAPUT
ODISHA. PIN-765013